

 Dominica Geothermal Development Company Limited <i>Powering a New Generation...</i>	Bid Clarification Request (In accordance with ITB 7.1)	Reference Number: RZ042100-PGG-COM-0002
Dominica Geothermal Risk Mitigation Project Contract		
Subject: Evaluation Criteria		
Bid Document Clause: Part 1 – Section III, Clause 1.2		
Detailed description of request Will DGDC only consider EPC costs to determinate the lowest evaluated cost, regardless of future costs associated with O&M? This is very important to choice the plant technology, because EPC cost of flash technology is cheaper than binary technology, but its cost of operation and maintenance will be more expensive for the owner of the power plant. Enclosures: None		
Response: Please refer to Part 1, Section III – Evaluation and Qualification Criteria which sets out the procedure used for evaluation. Specifically, as set out in Part 1, Section III, Clause 1.2 (b): Life Cycle Costs will not be evaluated. Enclosures: None		
This clarification does not require an Addendum to the Bid Document.		

Please acknowledge receipt of this clarification by completing the below information and returning to the sender:

Bidder Company Name _____

Bidder Contact Name _____

Date Received _____