

 Dominica Geothermal Development Company Limited <i>Powering a New Generation...</i>	Bid Clarification Request (In accordance with ITB 7.1)	Reference Number: RZ042100-PGG-COM-0008
Dominica Geothermal Risk Mitigation Project Contract		
Subject: Bid Clarification 0008 – Heat & Mass Balance, ambient temperature		
Bid Document Clause: Part 1, Section IV, Technical Schedules, item 1.1		
Detailed description of request Section IV - Bidding Forms, Technical Schedules, 1.1 Heat and Mass Balance Diagram: Please confirm that in case of binary technology proposed with Air Cooled Condenser, heat and mass balance shall be provided for the operation at maximum and minimum ambient dry bulb temperature, 100% load, all plant available.		
Enclosures: None		
Response: In the case of organic Rankine cycle technology, the heat and mass balance diagrams for the referenced conditions should be supplied for ambient dry bulb temperatures, not wet bulb.		
Enclosures: None		
This clarification does not require an Addendum to the Bid Document.		

Please acknowledge receipt of this clarification by completing the below information and returning to the sender:

Bidder Company Name _____

Bidder Contact Name _____

Date Received _____