

 Dominica Geothermal Development Company Limited Powering a New Generation...	Bid Clarification Request (In accordance with ITB 7.1)	Reference Number: RZ042100-PGG-COM-0017
Dominica Geothermal Risk Mitigation Project Contract		
Subject: Bid Clarification 0017 – Grid Connection		
Bid Document Clause: Part 2		
Detailed description of request In Part 2 page 769/1756, it is described the grid connection though un underground 11 KV line. However, in page 411/1756 in the interface schedule is it stated that DOLMEC is doing the connection to the grid and that the EPC contractor should bid up to and including the Plant switchgear outgoing connection busbars. Please confirm. Enclosures: None		
Response: The text quoted above from Page 768/1756 is extracted from the Environmental Social Impact Assessment (ESIA). The ESIA document is only included to give the Contractor context to the ESMP requirements which are included in Part 2, Section VII, sub-section 2 "Specification" that details the required scope and specification thereof. The Contractor scope includes design supply and installation of an 11kV main interconnect switchboard. DOMLEC will install the three incoming 11kV cables to this switchboard. The Contractor shall liaise with DOMLEC for completion of this interconnection work. The interface details are also shown on drawing RZ042100-GN-DRG-0004. Enclosures: None		
This clarification does not require an Addendum to the Bid Document.		

Please acknowledge receipt of this clarification by completing the below information and returning to the sender:

Bidder Company Name _____

Bidder Contact Name _____

Date Received _____