

 Dominica Geothermal Development Company Limited Powering a New Generation...	Bid Clarification Request (In accordance with ITB 7.1)	Reference Number: RZ042100-PGG-COM-0039
Dominica Geothermal Risk Mitigation Project Contract		
Subject: Bid Clarification 0039 - POWER PLANT CAPACITY		
Bid Document Clause: Section VII, page 60 paragraph 1.1		
Detailed description of request In section VII, page 60 paragraph 1.1 General Description of project, says that the geothermal resource has sufficient capacity to support operation of a nominal 7 MWe Gross, however in section III, page 43 the functional guarantee for each unit indicates that the Guaranteed Net Deliverable Capacity must be 3,500 kWe norm. Could you please confirm if the power plant capacity is 7 MWe net or gross? Enclosures: None		
Response: The output of the power plant is a function of the bidder's design. The maximum output for which a bidder will get credit under the evaluation criteria defined in Section III para 1.2.(c) is 3,500kWe net per unit. It is anticipated that the production well WW-P1 will only produce enough geothermal fluid to sustain a total output from the power plant of around 7,000kWe gross, hence the Contractor's commitment to the Performance Guarantees is only on a per-unit basis. Thus, the power plant capacity is twice the successful bidder's unit capacity. Enclosures: None		
This clarification does not require an Addendum to the Bid Document.		

Please acknowledge receipt of this clarification by completing the below information and returning to the sender:

Bidder Company Name _____

Bidder Contact Name _____

Date Received _____