



Dominica Geothermal
Development Company Limited
Powering a New Generation...

Bid Clarification Request (In accordance with ITB 7.1)

Reference Number:
RZ042100-PGG-COM-0053

Dominica Geothermal Risk Mitigation Project Contract

Subject: Bid Clarification 0053 - Hybrid system

Bid Document Clause: Specification Section 1.1.1

Detailed description of request

Please kindly confirm if we are allowed to offer a hybrid system of flash and ORC with a combination of 5MW flash and 2MW ORC.

We have found that this might offer some unique benefits.

Enclosures: None

The Employer's Requirements do not preclude a Bidder from offering a hybrid plant

Bidders attention is drawn to Section VII- Employers Requirements, Part 02 – Specification, Section 1.1.1: *“The Power Plant shall comprise of at least two Units and each unit shall have the same equal capacity.”* Bidders offering a hybrid solution would therefore need to provide a minimum of two Units with each Unit comprising a flash and ORC turbine/generator arrangement.

Enclosures:

This clarification does not require an Addendum to the Bid Document.

Please acknowledge receipt of this clarification by completing the below information and returning to the sender:

Bidder Company Name _____

Bidder Contact Name _____

Date Received _____